


TEST Report

REPORT NUMBER
170608010SHF-BP-11

ISSUE DATE
2017/8/25

PAGES
4

DOCUMENT CONTROL NUMBER
LFT-APAC-SHF-OP-10a
© 2017 INTERTEK



Test Report

Issue Date: 2017/8/25

Intertek Report No. 170608010SHF-BP-11

Applicant : ProGeneus Pty Ltd
 Applicant Address: 7, Winter Avenue Kellyville NSW 2155 Australia
 Attn: Zhengjin

SUBJECT: Performance testing
 Magnesium Mineral Board

Dear Sir,

This test report for represents the results of our evaluation of the above referenced product(s) to the requirements contained in the following standards:

TEST METHODS AND STANDARDS		
Refer to the next following Pages		

SAMPLE ID	MODEL	SPECIFICATION
S170608010SHF.001	/	2400mm*1200mm*6mm

SAMPLE RECEIEVED: 2017/4/24
 TESTED FROM: 2017/6/8 TO 2017/7/18

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Test Report

Issue Date: 2017/8/25

Intertek Report No. 170608010SHF-BP-11

Test Items, Method and Results:

Test Item	Test Method	Test Result
Chloride content	With reference to ASTM C871-11 ^{ε1}	0.0082%

Note:

1. The test was conducted at the external approved/qualified facility, located at [Nanjing].



Test Report

Issue Date: 2017/8/25


Intertek Report No. 170608010SHF-BP-11


APPENDIX: SAMPLE RECEIVED PHOTO




REPORT AUTHORIZED

When signed with physical or electronic signature, the contents of this report have been prepared and approved per Intertek's quality process in accordance with ISO 17025.


Name: Sun Sun
Title: Approver


Name: Daniel Zhang
Title: Reviewer


Name: Mason Wang
Title: Project Engineer

Revision:

NO.	DATE	CHANGES	AUTHOR	REVIEWER
170608010SHF-BP-11	2017/8/25	First issue	Mason Wang	Daniel Zhang

